



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING, VISAKHAPATNAM

From
The Commissioner,
Greater Visakhapatnam
Municipal Corporation
Visakhapatnam.

To
The Secretary,
Sanketika Vidya Parishad Engg.. College,
Sy. No: 61&62, PM Palem (v),
Madhurawada, Visakhapatnam.

Rc.No. 012646 /23/GVMC/FPW: Dt 03.02.2023

Sub: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing Visakhapatnam- of No Objection Certificate for Occupancy to the existing Educational building of **M/s SANKETIKA VIDYA PARISHAD ENGINEERING COLLEGE, Sy.No:61&62, PM Palem, Madhurawada, Visakhapatnam-530041 - Regarding.**

- Ref:** 1. Section 12(2) of Andhra Pradesh, Fire Services Act, 1999 and Rule 15(2) of Andhra Pradesh Fire & Emergency Operations and levy of Fee Rules,2006
2. Proceedings of the Director General of State Disaster Response and Fire Services Department of Rc.No.5041/B2/97 Dated:12.03.2010.
3. Proceedings of the Commissioner, GVMC, vide Rc.No.8626/09/c-12 Dt : 17.09.2009 and also dated 22.02.2010.
4. Representation of the Management of **M/s SANKETIKA VIDYA PARISHAD ENGINEERING COLLEGE, Sy.No:61&62, PM Palem, Madhurawada, Visakhapatnam.** Dated:10.01.2023.
5. Inspection Report of D.F.O., GVMC Dt: 18.01.2023.
6. Circular Memo of the Director General of State Disaster Response and Fire Services Department Rc. No. 1428/E2/2006, Dt: 10.02.2014.

Vide reference 4th cited **Sri Dr. S.V.H.Rajendra** has requested for Occupancy of Fire NOC for College building belongs to **M/s SANKETIKA VIDYA PARISHAD ENGINEERING COLLEGE, Sy.No:61&62, PM Palem, Madhurawada, Visakhapatnam.**

Vide reference 5th cited, the college was inspected on 18.01.2023 submit that there is No Objection to Occupancy of NOC to the above said College.

The Details of the Building is as follows:

i). **Address of the Buildings:** M/s SANKETIKA VIDYA PARISHAD ENGINEERING COLLEGE, Sy.No:61&62, PM Palem, Madhurawada, Visakhapatnam.

ii). **Measurements of the Buildings:**

- a) Height of the Building : 15.00 Mts
b) Plot Ares : 19117.67 Sq.Mts

iii) **Open Spaces**

Direction	Required as per G.O.No.168	Provided in Mts	Deficit
Front (South)	04.00 Meters	30.50 Meters	Nil
Rear (North)	03.00 Meters	22.50 Meters	
Side 1 (East)	03.00 Meters	06.00 Meters	
Side 2 (West)	03.00 Meters	06.00 Meters	

iv) **Fire Safety Measures:**

S1.No	Fire Safety Measures	Required as per Table 23 Of NBC of Indian 2005	Provided	Deficit
1	Fire Extinguishers	18 No Required	18 No Provided	Nil
2	Fire Buckets	18 No Required	18 No Provided	Nil
3	Public Address System	2 No Required	2 No Provide d	Nil
4	Terrace Tank of	50,000 Ltrs	50,000 Ltrs	Nil

V. BUILDING PLAN particulars:

Sl.No	Floor	Area in Sq.Mts	Occupancy	Occupant Load
1	BLOCK - I	7845.93 Sq mtrs	Educational	200
2	BLOCK - II	2195.24 Sq mtrs	Educational	50
3	BLOCK - III	5618.15 Sq mtrs	Educational	
4	BLOCK - IV	3458.35 Sq mtrs	Educational	
	Total Buildup Area	19117.67 Sq mtrs		250

Means of Escape:

External staircase: 1 Nos., 1.00 Meter.

The Fire Safety Systems were tested by The District Fire Officer along with S.F.O. personally. During the inspection and performance of the safety measures found satisfactory. Therefore, this office has No Objection for Occupancy the NOC to existing Educational M/s SANKETIKA VIDYA PARISHAD ENGINEERING COLLEGE, Sy.No:61&62, PM Palem, Madhurawada, Visakhapatnam.

Subject to the following conditions:

I	All the fire protection arrangements shall be maintained in good condition as seen during inspection. If any lapses found the NOC will be cancelled immediately.
II	All the escape/ exist routs shall not be kept locked/ blocked or encroached.
III	All the occupants must know the correct method of operation of the fire fighting system installed.
IV	Any loss of life or property due to non-functioning of fire safety measures and other installation shall be the responsibility of the management.
V	All students/ staff members of the intuition shall be trained to operate the fire safety equipments during emergency.
VI	Addition/ alteration, if any in the building may be obtained with prior permission from this Department.
VII	Mock Drill should be conducted once in 3 months for initial Two Years. Thereafter, once in every 6 months.
VIII	It is certified that the Fire Inspection and No Objection Certificate from Fire Prevention Wing, GVMC can't be claimed as right for the Building Regularization.
IX	The management shall obtain the building permission from the GVMC and this NOC cannot be construed as building permission or regularization of existing building.
X	This certificate is valid for TWO YEARS from the data of issue.

This No Objection Certificate for occupancy clearance is valid for two year from the data of issue of this letter. It is the responsibility of the builder to apply for clearance of NOC, duly remitting the user charges as per G.O. Ms.No.71, Home (Prison-A) department, dated of two months before expiry of this No Objection Certification


For ~~COMMISSIONER~~
Greater Visakhapatnam Municipal Corporation
Visakhapatnam
